



Battery Storage and Charging Area Inspection Checklist

Inspection Information			
Date and time:			
Date last inspected:			
Inspection done by:			
Signature:			
Battery Charging and Storage Area	Y / N	Corrective Action	Employee Responsible
Is an area designated for charging and storing batteries?			
Are "No Smoking" signs in place and clearly visible?			
Is the charging and storage area free of clutter?			
Are eye washing and emergency showering stations within 25 unobstructed feet of the charging and storage area?			
Is PPE (safety goggles, face shields, aprons, protective gloves, appropriate footwear, etc.) available?			
Is there adequate ventilation to prevent the accumulation of unsafe gas levels?			
Are batteries not in use stored in trays or spill containment areas?			
Is a stocked spill kit with neutralizing absorbents near the charging and storage area?			
Is material handling equipment (hoists, conveyors) available in good condition and properly related for better handling?			
Are brakes properly applied to charging equipment?			
Are battery storage racks and trays sturdy and resistant to battery acid?			
If applicable, are drums properly stacked?			
Are communication or warning devices properly working?			
Are flammable wastes properly stored and grounded/bonded?			
Other:			